



NOTICE

INSTALLATION OF GENERATOR SET IN RESIDENTIAL BUILDINGS

All the members are informed that in residential building a generator set may be installed as per following:-

- a. Generator Set to be installed in basement or front lawn 5 ft away from common boundary walls.
- b. Generator set must be installed with sound proof canopy and noise beyond the boundary limit shall not be more than 15 decibel.
- c. Maximum capacity of generator set is 25 KVA.
- d. Generator set will not be used as prime supply but only in failure of WAPDA / LESCO power supply.

Note: This supercedes all previous rulings /notice on this subject.

Secretary Technical & Chief Engineer
Defence Housing Authority
Lahore Cantt
02 May 2012